



Certificate of Compliance

Certificate: 1387930 (LR 19900-31)

Master Contract: 157828

Project: 70044324

Date Issued: 2015-10-08

Issued to: **Thomas & Betts Ltd.**
700 Thomas Ave
St-Jean-sur-Richelieu, Quebec J2X 2M9
CANADA
Attention: Mr. Harman Dhillon

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Michael Chung*
Michael Chung

PRODUCTS

CLASS 9032 02 - INSULATING DEVICES AND MATERIALS - Underground Cable Splicing Kits

Underground cable splicing kits for direct burial use, in rain-tight, water-tight and submersible locations:

Cat Nos 54, 54 SUPER, 54B, rated 25A, 5000V for use with Nos 2-12 AWG copper conductors.

Cat Nos 90P, 90R, 91P, 91R, rated 20A, 600V for use with Nos 8-16 AWG copper conductors.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 198.2-05, 2nd Ed - Sealed Wire Connector Systems