



CSA INTERNATIONAL

Certificate of Compliance

Certificate: 2055412 (LR33891)

Master Contract: 157828

Project: 2055412

Date Issued: 2008/09/16

Issued to: Amerace, A Div of
Thomas & Betts (Ontario) Ltd
77 W Beaver Creek Rd
Richmond Hill, ON L4B 3A7
Canada
Attention: Mr. Harman Dhillon

The products listed below are eligible to bear the CSA Mark shown



Issued by: Johann Borabon

Authorized by: Nick Alfano, Operations
Manager

PRODUCTS

CLASS 5411 06 - TRANSFORMERS-Power

Series Isolating Transformer for Airport Lighting, TPR/TPE/TPV encapsulated, with moulded-in lead and connector combination, 5kV insulation:

Cat No*	Wattage, W	Primary/Secondary Amperage, A	Frequency, Hz
TAG045666**+	30/45	6.6/6.6	50/60
TAG045666	30/45	6.6/6.6	60
TAG045666D**+	30/45	6.6/6.6	50/60



CSA INTERNATIONAL

Certificate: 2055412 (LR33891)

Master Contract: 157828

Project: 2055412

Date Issued: 2008/09/16

TAG065666	65	6.6/6.6	60
TAG100666**	100	6.6/6.6	50/60
TAG150666	150	6.6/6.6	60
TAG200666	200	6.6/6.6	60
TAG200665	200	6.6/6.6	50
TAG250626	250	6.6/20	60
TAG300666	300	6.6/6.6	60

Notes:

1. * The catalogue number is followed either by the suffixes '01' or '10'. Also it may be prefixed with the letter C.
2. ** For 50/60Hz rated units, the last digit "6" in the Cat No. may be replaced by the letter "D".
3. + The TAG045666 and the TAG04566D units come in two designs but both have the same model number on them. They are using a specific bobbin design that can be tracked through the date code as seen on the units.

APPLICABLE REQUIREMENTS

CSA Std.C22.2 No.180 - Series Isolating Transformers for Airport Lighting